



SUSANA MARTINEZ
Governor

JOHN A. SANCHEZ
Lieutenant Governor

**NEW MEXICO
ENVIRONMENT DEPARTMENT**

Harold Runnels Building
1190 South St. Francis Drive (87505)
P.O. Box 5469, Santa Fe, New Mexico 87502-5469
Phone (505) 827-2900 Fax (505) 827-2965
www.env.nm.gov



BUTCH TONGATE
Cabinet Secretary

J.C. BORREGO
Deputy Secretary

CERTIFIED MAIL – RETURN RECEIPT REQUESTED

March 3, 2017

Kimberly Visser-Weinmann, General Manager
Las Campanas Water and Sewer Cooperative
366 Las Campanas Drive
Santa Fe, New Mexico 87506

RE: Draft Discharge Permit Renewal, DP-944, Las Campanas Water and Sewer Cooperative

Dear Ms. Visser-Weinmann:

Notice is hereby given pursuant to Subsection H of 20.6.2.3108 NMAC that Ground Water Discharge Permit Renewal, DP-944, to the Las Campanas Water and Sewer Cooperative, has been proposed for approval (copy enclosed). The New Mexico Environment Department (NMED) will publish notice of the availability of the draft Discharge Permit in the near future and will forward a copy of the notice to you.

Prior to making a final ruling on the proposed Discharge Permit, NMED will allow 30 days from the date the public notice is published during which time written comments can be submitted and/or a public hearing requested. Comments and/or hearing requests may be submitted by any interested person, including the Discharge Permit applicant. Written comments and/or hearing requests must be submitted to the Ground Water Quality Bureau at the address above and shall set forth the reasons why a hearing is requested. A hearing will be held only if hearing requests are received from the public and/or the Discharge Permit applicant during the 30-day comment period and NMED determines there is substantial public interest in the proposed Discharge Permit. Hearings are presided over by the NMED Secretary or a hearing officer appointed by the Secretary.

Please review the enclosed draft Discharge Permit carefully to understand your responsibilities pursuant to the Discharge Permit. Please be aware that this Discharge Permit may contain conditions that require the permittee to implement operational, monitoring or closure actions by a

Kimberly Visser-Weinmann, General Manager
Las Campanas Water and Sewer Cooperative
March 3, 2017
Page 2 of 2

specified deadline. Please note any inaccuracies or concerns, and submit any comments to NMED Ground Water Quality Bureau.

A copy of the Water Quality Control Commission (WQCC) Regulations, 20.6.2 NMAC, is available at http://www.nmcpr.state.nm.us/nmac/_title20/T20C006.htm.

If you have any comments, questions, or concerns, please contact me at (505) 827-0018. If written comments and/or a written request for hearing are not received during the public comment period, the draft Discharge Permit will become final. Thank you for your cooperation during the review process.

Sincerely,



R. Brian Schall
Hydrologist Supervisor

enc: Draft Discharge Permit Renewal, DP-944

cc: Larry Cox, Operations Manager, Las Campanas Water and Sewer Cooperative, 366 Las Campanas Drive, Santa Fe, NM 87506
Gerardo L. Gonzalez Ortiz, Project Manager, CH2M Hill OM Services, 428-B Las Campanas Drive, Santa Fe, NM 87506
Meghan Hodgins, Project Manager, Glorieta Geosciences, Inc., P.O. Box 5727, Santa Fe, NM 87502
Andrew Knight, NMED-OGC

GROUND WATER DISCHARGE PERMIT RENEWAL
Las Campanas Water and Sewer Cooperative, DP-944

I. INTRODUCTION

The New Mexico Environment Department (NMED) issues this Discharge Permit Renewal (Discharge Permit), DP-944, to the Las Campanas Water and Sewer Cooperative (permittee) pursuant to the New Mexico Water Quality Act (WQA), NMSA 1978 §§74-6-1 through 74-6-17, and the New Mexico Water Quality Control Commission (WQCC) Regulations, 20.6.2 NMAC.

NMED's purpose in issuing this Discharge Permit, and in imposing the requirements and conditions specified herein, is to control the discharge of water contaminants from the Las Campanas Water and Sewer Cooperative Wastewater Treatment Plant (facility) into ground and surface waters, so as to protect ground and surface waters for present and potential future use as domestic and agricultural water supply and other uses and protect public health. In issuing this Discharge Permit, NMED has determined that the requirements of Subsection C of 20.6.2.3109 NMAC have been or will be met. Pursuant to Section 20.6.2.3104 NMAC, it is the responsibility of the permittee to comply with the terms and conditions of this Discharge Permit; failure may result in an enforcement action(s) by NMED (20.6.2.1220 NMAC).

The activities that produce the discharge, the location of the discharge, and the quantity, quality and flow characteristics of the discharge are briefly described as follows.

Up to 320,000 gallons per day (gpd) of domestic wastewater is received and treated using an activated sludge wastewater treatment plant. Treated wastewater (reclaimed wastewater) is discharged to a synthetically-lined impoundment (Lake 5W) on the property of The Club at Las Campanas where the reclaimed wastewater is blended with Rio Grande raw water prior to being used for the irrigation of approximately 45 acres of fairways and greens on The Club at Las Campanas golf course. Treated wastewater that does not meet reclaimed wastewater quality is discharged to a synthetically-lined impoundment (Impoundment #1) on the property of the Las Campanas Water and Sewer Cooperative for disposal by evaporation or to be returned to the wastewater treatment plant for further treatment.

The discharge contains water contaminants that may be elevated above the standards of Section 20.6.2.3103 NMAC and/or the presence of toxic pollutants as defined in Subsection WW of 20.6.2.7 NMAC.

The facility is located at 428 Las Campanas Drive, approximately six miles northwest of Santa Fe, in Section 15, Township 17N, Range 8E, Santa Fe County. Groundwater most likely to be affected is at a depth of approximately 278 feet and has a total dissolved solids concentration of approximately 300 milligrams per liter.

The original Discharge Permit was issued on August 13, 1993 and subsequently amended on September 15, 1993, renewed on March 16, 2001, modified on June 21, 2002, modified on July 9, 2003, amended on June 21, 2004, and renewed and modified on June 26, 2007. The application (i.e., discharge plan) consists of the materials submitted by the permittee dated February 10, 2012 and materials contained in the administrative record prior to issuance of this

Discharge Permit. The discharge shall be managed in accordance with all conditions and requirements of this Discharge Permit.

Pursuant to Section 20.6.2.3109 NMAC, NMED reserves the right to require a Discharge Permit Modification in the event NMED determines that the requirements of 20.6.2 NMAC are being or may be violated or the standards of Section 20.6.2.3103 NMAC are being or may be violated. This may include a determination that structural controls and/or management practices approved under this Discharge Permit are not protective of groundwater quality, and that more stringent requirements to protect groundwater quality may be required by NMED. The permittee may be required to implement abatement of water pollution and remediate groundwater quality.

Issuance of this Discharge Permit does not relieve the permittee of the responsibility to comply with the WQA, WQCC Regulations, and any other applicable federal, state and/or local laws and regulations, such as zoning requirements and nuisance ordinances.

The following acronyms and abbreviations may be used in this Discharge Permit:

Abbreviation	Explanation	Abbreviation	Explanation
BOD ₅	biochemical oxygen demand (5-day)	NMED	New Mexico Environment Department
CFR	Code of Federal Regulations	NMSA	New Mexico Statutes Annotated
CFU	Colony Forming Unit	NO ₃ -N	nitrate-nitrogen
Cl	chloride	NTU	nephelometric turbidity units
EPA	United States Environmental Protection Agency	TDS	total dissolved solids
gpd	gallons per day	TKN	total Kjeldahl nitrogen
LAA	land application area	total nitrogen	= TKN + NO ₃ -N
LADS	land application data sheet(s)	TRC	Total Residual Chlorine
mg/L	milligrams per liter	TSS	total suspended solids
mL	milliliters	WQA	New Mexico Water Quality Act
MPN	Most Probable Number	WQCC	Water Quality Control Commission
NMAC	New Mexico Administrative Code	WWTF	Wastewater Treatment Facility

II. FINDINGS

In issuing this Discharge Permit, NMED finds:

1. The permittee is discharging effluent or leachate from the facility so that such effluent or leachate may move directly or indirectly into groundwater within the meaning of Section 20.6.2.3104 NMAC.
2. The permittee is discharging effluent or leachate from the facility so that such effluent or leachate may move into groundwater of the State of New Mexico that has an existing

concentration of 10,000 mg/L or less of TDS within the meaning of Subsection A of 20.6.2.3101 NMAC.

3. The discharge from the facility is not subject to any of the exemptions of Section 20.6.2.3105 NMAC.

III. AUTHORIZATION TO DISCHARGE

Pursuant to 20.6.2.3104 NMAC, it is the responsibility of the permittee to ensure that discharges authorized by this Discharge Permit are consistent with the terms and conditions herein.

The permittee is authorized to receive and treat up to 320,000 gpd of domestic wastewater using an activated sludge wastewater treatment plant. The permittee is authorized to discharge treated wastewater (reclaimed wastewater) to a synthetically-lined impoundment (Lake 5W) on the property of The Club at Las Campanas where the reclaimed wastewater is blended with Rio Grande raw water prior to being used for the irrigation of approximately 45 acres of fairways and greens on The Club at Las Campanas golf course. Treated wastewater that does not meet reclaimed wastewater quality is discharged to a synthetically-lined impoundment (Impoundment #1) on the property of the Las Campanas Water and Sewer Cooperative for disposal by evaporation or to be returned to the wastewater treatment plant for further treatment.

[20.6.2.3104 NMAC, Subsection C of 20.6.2.3106 NMAC, Subsection C of 20.6.2.3109 NMAC]

IV. CONDITIONS

NMED issues this Discharge Permit for the discharge of water contaminants subject to the following conditions.

A. OPERATIONAL PLAN

#	Terms and Conditions
1.	<p>The permittee shall implement the following operational plan to ensure compliance with Title 20, Chapter 6, Parts 1 and 2 NMAC.</p> <p>[Subsection C of 20.6.2.3109 NMAC]</p>
2.	<p>The permittee shall operate in a manner such that standards and requirements of Sections 20.6.2.3101 and 20.6.2.3103 NMAC are not violated.</p> <p>[20.6.2.3101 NMAC, 20.6.2.3103 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>

Operating Conditions

#	Terms and Conditions																																				
3.	<p>Reclaimed wastewater discharged from the final treatment process shall not exceed the following discharge limit.</p> <p>Total Nitrogen: 15 mg/L</p> <p>[Subsection C of 20.6.2.3109 NMAC]</p>																																				
4.	<p>Reclaimed wastewater discharged from the final treatment process shall not exceed the following discharge limits:</p> <table><tr><th>Test</th><th>30-day Average</th><th>Maximum</th></tr><tr><td>Fecal coliform:</td><td>100 CFU/100 mL</td><td>200 CFU/100 mL</td></tr><tr><td>BOD₅:</td><td>30 mg/L</td><td>45 mg/L</td></tr><tr><td>TSS:</td><td>30 mg/L</td><td>45 mg/L</td></tr><tr><td>TRC:</td><td>Monitor Only</td><td>Monitor Only</td></tr></table> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>	Test	30-day Average	Maximum	Fecal coliform:	100 CFU/100 mL	200 CFU/100 mL	BOD ₅ :	30 mg/L	45 mg/L	TSS:	30 mg/L	45 mg/L	TRC:	Monitor Only	Monitor Only																					
Test	30-day Average	Maximum																																			
Fecal coliform:	100 CFU/100 mL	200 CFU/100 mL																																			
BOD ₅ :	30 mg/L	45 mg/L																																			
TSS:	30 mg/L	45 mg/L																																			
TRC:	Monitor Only	Monitor Only																																			
5.	<p>Reclaimed wastewater discharged from the final treatment process shall not exceed the following discharge limits.</p> <table><tr><th>Contaminants</th><th>20.6.2.3103 Standards</th></tr><tr><td>Aluminum</td><td>5.0 mg/L</td></tr><tr><td>Arsenic</td><td>0.1 mg/L</td></tr><tr><td>Barium</td><td>1.0 mg/L</td></tr><tr><td>Boron</td><td>0.75 mg/L</td></tr><tr><td>Cadmium</td><td>0.01 mg/L</td></tr><tr><td>Chromium</td><td>0.05 mg/L</td></tr><tr><td>Cobalt</td><td>0.05 mg/L</td></tr><tr><td>Copper</td><td>1.0 mg/L</td></tr><tr><td>Cyanide</td><td>0.2 mg/L</td></tr><tr><td>Fluoride</td><td>1.6 mg/L</td></tr><tr><td>Iron</td><td>1.0 mg/L</td></tr><tr><td>Lead</td><td>0.05 mg/L</td></tr><tr><td>Manganese</td><td>0.2 mg/L</td></tr><tr><td>Molybdenum</td><td>1.0 mg/L</td></tr><tr><td>Total Mercury (Hg)</td><td>0.002 mg/L</td></tr><tr><td>Nickel</td><td>0.2 mg/L</td></tr><tr><td>Selenium</td><td>0.05 mg/L</td></tr></table>	Contaminants	20.6.2.3103 Standards	Aluminum	5.0 mg/L	Arsenic	0.1 mg/L	Barium	1.0 mg/L	Boron	0.75 mg/L	Cadmium	0.01 mg/L	Chromium	0.05 mg/L	Cobalt	0.05 mg/L	Copper	1.0 mg/L	Cyanide	0.2 mg/L	Fluoride	1.6 mg/L	Iron	1.0 mg/L	Lead	0.05 mg/L	Manganese	0.2 mg/L	Molybdenum	1.0 mg/L	Total Mercury (Hg)	0.002 mg/L	Nickel	0.2 mg/L	Selenium	0.05 mg/L
Contaminants	20.6.2.3103 Standards																																				
Aluminum	5.0 mg/L																																				
Arsenic	0.1 mg/L																																				
Barium	1.0 mg/L																																				
Boron	0.75 mg/L																																				
Cadmium	0.01 mg/L																																				
Chromium	0.05 mg/L																																				
Cobalt	0.05 mg/L																																				
Copper	1.0 mg/L																																				
Cyanide	0.2 mg/L																																				
Fluoride	1.6 mg/L																																				
Iron	1.0 mg/L																																				
Lead	0.05 mg/L																																				
Manganese	0.2 mg/L																																				
Molybdenum	1.0 mg/L																																				
Total Mercury (Hg)	0.002 mg/L																																				
Nickel	0.2 mg/L																																				
Selenium	0.05 mg/L																																				

#	Terms and Conditions																																																		
	<table> <tr><td>Silver</td><td>0.05 mg/L</td></tr> <tr><td>Sulfate</td><td>600.0 mg/L</td></tr> <tr><td>Uranium</td><td>0.03 mg/L</td></tr> <tr><td>Zinc</td><td>10.0 mg/L</td></tr> <tr><td>Benzene</td><td>0.01 mg/L</td></tr> <tr><td>Benzo(a)pyrene</td><td>0.0007 mg/L</td></tr> <tr><td>Carbon tetrachloride</td><td>0.01 mg/L</td></tr> <tr><td>Chloroform</td><td>0.1 mg/L</td></tr> <tr><td>1,1-Dichloroethane</td><td>0.025 mg/L</td></tr> <tr><td>1,2-Dichloroethane (EDC)</td><td>0.01 mg/L</td></tr> <tr><td>1,1-Dichloroethylene (1,1 DCE)</td><td>0.005 mg/L</td></tr> <tr><td>Ethylbenzene</td><td>0.75 mg/L</td></tr> <tr><td>Ethylene dibromide (EDB)</td><td>0.0001 mg/L</td></tr> <tr><td>Methylene chloride</td><td>0.1 mg/L</td></tr> <tr><td>PAHs: Naphthalene plus monomethylnaphthalenes</td><td>0.03 mg/L</td></tr> <tr><td>Phenols</td><td>0.005 mg/L</td></tr> <tr><td>Polychlorinated biphenyls (PCBs)</td><td>0.001 mg/L</td></tr> <tr><td>Toluene</td><td>0.75 mg/L</td></tr> <tr><td>1,1,2,2-tetrachloroethane (PCE)</td><td>0.02 mg/L</td></tr> <tr><td>1,1,1-Trichloroethane</td><td>0.06 mg/L</td></tr> <tr><td>1,1,2-Trichloroethane</td><td>0.01 mg/L</td></tr> <tr><td>Trichloroethylene (TCE)</td><td>0.005 mg/L</td></tr> <tr><td>Vinyl Chloride</td><td>0.001 mg/L</td></tr> <tr><td>Xylenes (total)</td><td>0.62 mg/L</td></tr> <tr><td>Radioactivity: Radium 226 and 228 (combined)</td><td>30 picocuries per Liter</td></tr> </table>	Silver	0.05 mg/L	Sulfate	600.0 mg/L	Uranium	0.03 mg/L	Zinc	10.0 mg/L	Benzene	0.01 mg/L	Benzo(a)pyrene	0.0007 mg/L	Carbon tetrachloride	0.01 mg/L	Chloroform	0.1 mg/L	1,1-Dichloroethane	0.025 mg/L	1,2-Dichloroethane (EDC)	0.01 mg/L	1,1-Dichloroethylene (1,1 DCE)	0.005 mg/L	Ethylbenzene	0.75 mg/L	Ethylene dibromide (EDB)	0.0001 mg/L	Methylene chloride	0.1 mg/L	PAHs: Naphthalene plus monomethylnaphthalenes	0.03 mg/L	Phenols	0.005 mg/L	Polychlorinated biphenyls (PCBs)	0.001 mg/L	Toluene	0.75 mg/L	1,1,2,2-tetrachloroethane (PCE)	0.02 mg/L	1,1,1-Trichloroethane	0.06 mg/L	1,1,2-Trichloroethane	0.01 mg/L	Trichloroethylene (TCE)	0.005 mg/L	Vinyl Chloride	0.001 mg/L	Xylenes (total)	0.62 mg/L	Radioactivity: Radium 226 and 228 (combined)	30 picocuries per Liter
Silver	0.05 mg/L																																																		
Sulfate	600.0 mg/L																																																		
Uranium	0.03 mg/L																																																		
Zinc	10.0 mg/L																																																		
Benzene	0.01 mg/L																																																		
Benzo(a)pyrene	0.0007 mg/L																																																		
Carbon tetrachloride	0.01 mg/L																																																		
Chloroform	0.1 mg/L																																																		
1,1-Dichloroethane	0.025 mg/L																																																		
1,2-Dichloroethane (EDC)	0.01 mg/L																																																		
1,1-Dichloroethylene (1,1 DCE)	0.005 mg/L																																																		
Ethylbenzene	0.75 mg/L																																																		
Ethylene dibromide (EDB)	0.0001 mg/L																																																		
Methylene chloride	0.1 mg/L																																																		
PAHs: Naphthalene plus monomethylnaphthalenes	0.03 mg/L																																																		
Phenols	0.005 mg/L																																																		
Polychlorinated biphenyls (PCBs)	0.001 mg/L																																																		
Toluene	0.75 mg/L																																																		
1,1,2,2-tetrachloroethane (PCE)	0.02 mg/L																																																		
1,1,1-Trichloroethane	0.06 mg/L																																																		
1,1,2-Trichloroethane	0.01 mg/L																																																		
Trichloroethylene (TCE)	0.005 mg/L																																																		
Vinyl Chloride	0.001 mg/L																																																		
Xylenes (total)	0.62 mg/L																																																		
Radioactivity: Radium 226 and 228 (combined)	30 picocuries per Liter																																																		
	[Subsection C of 20.6.2.3109 NMAC]																																																		
6.	<p>The permittee shall institute a backflow prevention method to protect wells and public water supply systems from contamination by reclaimed wastewater prior to discharging to The Club at Las Campanas golf course. Backflow prevention shall be achieved by a total disconnect (physical air gap separation between the discharge pipe and the liquid surface at least twice the diameter of the discharge pipe), or by a reduced pressure principal backflow prevention assembly (RP) installed on the line between the fresh water supply wells or public water supply and the reclaimed wastewater delivery system. Backflow prevention shall be maintained at all times.</p> <p>RP devices shall be inspected and tested by a certified backflow prevention assembly tester at the time of installation, repair or relocation and at least on an annual basis thereafter. The backflow prevention assembly tester shall have successfully completed a 40-hour backflow prevention course based on the University of Southern California's Backflow Prevention Standards and Test Procedures, and obtained certification</p>																																																		

#	Terms and Conditions
	<p>demonstrating completion. A malfunctioning RP device shall be repaired or replaced within 30 days of discovery, and use of all supply lines associated with the RP device shall cease until repair or replacement has been completed. Copies of the inspection and maintenance records and test results for each RP device associated with the backflow prevention program shall be maintained at a location available for inspection by NMED.</p> <p>[Subsection C of 20.6.2.3109 NMAC]</p>
7.	<p>The permittee shall maintain fences around the facility to control access by the general public and animals. The fences shall consist of a minimum of six-foot chain link or field fencing and locking gates. Fences shall be maintained throughout the term of this Discharge Permit.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>
8.	<p>The permittee shall maintain signs indicating that the wastewater at the facility is not potable. Signs shall be posted at the facility entrance and other areas where there is potential for public contact with wastewater. All signs shall be printed in English and Spanish remain visible and legible for the term of this Discharge Permit.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>
9.	<p>The permittee shall maintain the impoundment liner(s) for Impoundment #1 in such a manner as to avoid conditions that could affect the structural integrity of the impoundment(s) and/or impoundment liner(s). Such conditions include or may be characterized by the following:</p> <ul style="list-style-type: none"> • erosion damage; • animal burrows or other damage; • the presence of vegetation including aquatic plants, weeds, woody shrubs or trees growing within five feet of the top inside edge of a sub-grade impoundment, within five feet of the toe of the outside berm of an above-grade impoundment, or within the impoundment itself; • the presence of large debris or large quantities of debris in the impoundment; • evidence of seepage; or • evidence of berm subsidence. <p>Vegetation growing around the impoundment(s) shall be routinely controlled by mechanical removal in a manner that is protective of the impoundment liner.</p> <p>The permittee shall visually inspect the impoundment(s) and surrounding berms on a monthly basis to ensure proper maintenance. In the event that inspection reveals any evidence of damage that threatens the structural integrity of an impoundment berm or liner, or that may result in an unauthorized discharge, the permittee shall enact the contingency plan set forth in this Discharge Permit.</p>

#	Terms and Conditions
	[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
10.	<p>The permittee shall preserve a minimum of two feet of freeboard between the liquid level in Impoundment #1 and the elevation of the top of the impoundment liner. In the event that the permittee determines that two feet of freeboard cannot be preserved in the impoundment, the permittee shall enact the contingency plan set forth in this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
11.	<p>The permittee shall properly manage all solids generated by the treatment system to maintain effective operation by removing solids as necessary in accordance with accepted process control methods. Solids removed from the treatment process shall be contained, transported, and disposed of in accordance with all local, state, and federal regulations. The permittee shall maintain records of solids disposal.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
12.	<p>The permittee shall inspect the lift station(s) on a quarterly basis, and clean as needed to prevent pump failure. The permittee shall maintain a record of lift station inspections, repairs and cleanings.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
13.	<p>The permittee shall utilize operators, certified by the State of New Mexico at the appropriate level, to operate the wastewater collection, treatment and disposal systems. The operations and maintenance of all or any part of the wastewater system shall be performed by, or under the direct supervision of, a certified operator.</p> <p>[Subsection C of 20.6.2.3109 NMAC, 20.7.4 NMAC]</p>
14.	<p>The following general requirements for above-ground use of reclaimed domestic wastewater shall be met.</p> <ol style="list-style-type: none"> Signs, in English and Spanish, shall be maintained at all re-use areas such that they are visible and legible for the term of this Discharge Permit. The signs shall be posted at the entrance to re-use areas and at other locations where public exposure to reclaimed domestic wastewater may occur. The signs shall state: NOTICE: THIS AREA IS IRRIGATED WITH RECLAIMED WASTEWATER - DO NOT DRINK. AVISO: ESTA ÁREA ESTÁ REGADA CON AGUAS NEGRAS RECOBRADAS - NO TOMAR. Alternate wording and/or graphics may be submitted to NMED for approval. The reclaimed domestic wastewater systems shall have no direct or indirect cross connections with public water systems or irrigation wells pursuant to the latest revision of the New Mexico Plumbing Code (14.8.2 NMAC) and New Mexico

#	Terms and Conditions
	<p>Mechanical Code (14.9.2 NAMC).</p> <ul style="list-style-type: none"> c) Above-ground use of reclaimed domestic wastewater shall not result in excessive ponding of wastewater, and shall not exceed the water consumptive needs of the crop. Re-use shall not be conducted at times when the re-use area is saturated or frozen. d) The discharge of reclaimed domestic wastewater shall be confined to the re-use area. e) The discharge of reclaimed domestic wastewater to crops for human consumption is prohibited. f) Water supply wells within 200 feet of a re-use area shall have adequate wellhead construction pursuant to 19.27.4 NMAC. Re-use shall be managed to ensure protection of groundwater quality. g) Existing and accessible portions of the reclaimed domestic wastewater distribution system (with the exception of application equipment such as sprinklers or pivots) shall be colored purple or clearly labeled as being part of a reclaimed domestic wastewater distribution system. Piping, valves and outlets that are installed during the term of this Discharge Permit shall be colored purple pursuant to the latest revision of the New Mexico Plumbing Code (14.8.2 NMAC) and New Mexico Mechanical Code (14.9.2 NAMC) to differentiate piping or fixtures used to convey reclaimed wastewater from those intended for potable or other uses. Valves, outlets, and sprinkler heads used in reclaimed wastewater systems shall be accessible only to authorized personnel. <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>
15.	<p>The following setbacks, access restrictions and equipment requirements for spray irrigation using Class 1B reclaimed domestic wastewater shall be met.</p> <ul style="list-style-type: none"> a) A minimum 100-foot setback shall be maintained between any dwellings or occupied establishments and the edge of the re-use area. b) Irrigation using reclaimed domestic wastewater shall be postponed at times when windy conditions may result in drift of reclaimed wastewater outside the re-use area. c) Reclaimed domestic wastewater shall be applied at times and in a manner that minimizes public contact. d) The spray irrigation system shall be limited to low trajectory spray nozzles. <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>
16.	<p>Reclaimed domestic wastewater shall be applied evenly throughout the entire re-use area such that the amount of total nitrogen applied does not exceed 200 pounds per acre in any 12-month period. Excessive ponding shall be prevented. Nitrogen content shall not be adjusted to account for volatilization or mineralization processes.</p> <p>[Subsection C of 20.6.2.3109 NMAC]</p>

B. MONITORING AND REPORTING

#	Terms and Conditions
17.	<p>The permittee shall conduct the following monitoring, reporting, and other requirements listed below in accordance with the monitoring requirements of this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
18.	<p>METHODOLOGY – Unless otherwise approved in writing by NMED, the permittee shall conduct sampling and analysis in accordance with the most recent edition of the following documents.</p> <ul style="list-style-type: none"> a) American Public Health Association, <i>Standard Methods for the Examination of Water and Wastewater</i> (18th, 19th or current) b) U.S. Environmental Protection Agency, <i>Methods for Chemical Analysis of Water and Waste</i> c) U.S. Geological Survey, <i>Techniques for Water Resources Investigations of the U.S. Geological Survey</i> d) American Society for Testing and Materials, <i>Annual Book of ASTM Standards, Part 31. Water</i> e) U.S. Geological Survey, et al., <i>National Handbook of Recommended Methods for Water Data Acquisition</i> f) <i>Federal Register</i>, latest methods published for monitoring pursuant to Resource Conservation and Recovery Act regulations g) <i>Methods of Soil Analysis: Part 1. Physical and Mineralogical Methods; Part 2. Microbiological and Biochemical Properties; Part 3. Chemical Methods</i>, American Society of Agronomy <p>[Subsection B of 20.6.2.3107 NMAC]</p>
19.	<p>The permittee shall submit quarterly monitoring reports to NMED for the most recently completed quarterly period by the 1st of February, May, August and November each year.</p> <p>Quarterly monitoring shall be performed during the following periods and submitted as follows:</p> <ul style="list-style-type: none"> • January 1st through March 31st (first quarter) – due by May 1st; • April 1st through June 30th (second quarter) – due by August 1st; • July 1st through September 30th (third quarter) – due by November 1st; and • October 1st through December 31st (fourth quarter) – due by February 1st. <p>[Subsection A of 20.6.2.3107 NMAC]</p>

Facility Monitoring Conditions

#	Terms and Conditions
20.	<p>The permittee shall measure the total monthly volume, calculate the daily average volume and record the daily peak volume of wastewater received by the treatment system each month using a primary measuring device (equipped with head sensing, totalizing and chart recording/data logging mechanisms) located on the influent line to the wastewater treatment plant.</p> <p>The totalized, average daily and peak daily discharge volumes for each month shall be submitted to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
21.	<p>The permittee shall measure the monthly volume of wastewater discharged from the treatment system to Impoundment #1. The permittee shall obtain readings from a totalizing flow meter located discharge line on a monthly basis and calculate the monthly and average daily discharge volume.</p> <p>The monthly meter readings, and calculated monthly and average daily discharge volumes shall be submitted to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
22.	<p>The permittee shall measure the monthly volume of reclaimed wastewater discharged from the treatment system to Lake 5W. The permittee shall obtain readings from a totalizing flow meter located at pump station 5W on a monthly basis and calculate the monthly and average daily discharge volume.</p> <p>The monthly meter readings, and calculated monthly and average daily discharge volumes shall be submitted to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
23.	<p>All flow meters shall be capable of having their accuracy verified under actual working (field) conditions. A field verification method shall be developed for each flow meter and that method shall be used to check the accuracy of each respective meter. Field calibrations shall be performed upon repair or replacement of a flow measurement device and, at a minimum, within 90 days of the effective date of this Discharge Permit (by DATE), and then every year thereafter.</p> <p>Flow meters shall be calibrated to within plus or minus 10 percent of actual flow, as measured under field conditions. Field calibrations shall be performed by an individual knowledgeable in flow measurement and in the installation/operation of the particular device in use. A flow meter calibration report shall be prepared for each flow</p>

#	Terms and Conditions
	<p>measurement device at the frequency calibration is required. The flow meter calibration report shall include the following information.</p> <ol style="list-style-type: none"> The location and meter identification. The method of flow meter field calibration employed. The measured accuracy of each flow meter prior to adjustment indicating the positive or negative offset as a percentage of actual flow as determined by an in-field calibration check. The measured accuracy of each flow meter following adjustment, if necessary, indicating the positive or negative offset as a percentage of actual flow of the meter. Any flow meter repairs made during the previous year or during field calibration. <p>The permittee shall maintain records of flow meter calibration(s) at a location accessible for review by NMED during facility inspections.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
24.	<p>The permittee shall visually inspect flow meters on a monthly basis for evidence of malfunction. If a visual inspection indicates a flow meter is not functioning as required by this Discharge Permit, the permittee shall repair or replace the meter within 30 days of discovery. For <i>repaired</i> meters, the permittee shall submit a report to NMED with the next monitoring report following the repair that includes a description of the malfunction; a statement verifying the repair; and a flow meter field calibration report completed in accordance with the requirements of this Discharge Permit. For <i>replacement</i> meters, the permittee shall submit a report to NMED with the next monitoring report following the replacement that includes a design schematic for the device and a flow meter field calibration report completed in accordance with the requirements of this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
25.	<p>The permittee shall collect grab samples of reclaimed wastewater from pump station 5W on a quarterly basis and analyze the samples for:</p> <ul style="list-style-type: none"> TKN; NO₃-N; TDS; and Cl. <p>Samples shall be properly prepared, preserved, transported and analyzed in accordance with the methods authorized in this Discharge Permit. Analytical results shall be submitted to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
26.	<p>During any week that the discharge of reclaimed wastewater occurs, the permittee shall</p>

#	Terms and Conditions
	<p>perform the following analyses on reclaimed wastewater samples collected at pump station 5W using the following sampling method and frequency:</p> <ul style="list-style-type: none"> • Fecal coliform bacteria: grab sample at peak daily flow once per week; • BOD₅: six-hour composite sample once every two weeks; • TSS: six-hour composite sample once every two weeks; • TRC concentrations: record whenever fecal coliform samples are collected. <p>Samples shall be properly prepared, preserved, transported and analyzed in accordance with the methods authorized in this Discharge Permit. Analytical results and a copy of the log of TRC concentrations shall be submitted to NMED in the quarterly monitoring reports.</p> <p>In the event that a discharge does not occur during any calendar week to Lake 5W, sampling and analysis need not be performed. Report 'No Discharge' on the quarterly monitoring report.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections B, C and H of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>
27.	<p>On an annual basis, the permittee shall collect a 24-hour flow weighted composite sample (except where noted) of reclaimed wastewater from the final treatment process and analyze the sample for the following inorganic constituents:</p> <ul style="list-style-type: none"> • aluminum • arsenic • barium • boron • cadmium • chromium • cobalt • copper • cyanide • fluoride • iron • lead • manganese • molybdenum • mercury • pH (instantaneous) • nickel • radioactivity: combined radium-226 & radium-228 • selenium • silver • sulfate • uranium • zinc <p>Samples shall be properly prepared, preserved, transported and analyzed in accordance with the methods authorized in this Discharge Permit. Analytical results shall be submitted to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
28.	<p>On an annual basis, the permittee shall collect a grab sample of reclaimed wastewater from the final treatment process and analyze the sample for the following organic</p>

#	Terms and Conditions
	<p>constituents:</p> <ul style="list-style-type: none"> • benzene • benzo-a-pyrene • carbon tetrachloride • chloroform • 1,1-dichloroethane • 1,2-dichloroethane (EDC) • 1,1-dichloroethylene (1,1-DCE) • ethylbenzene • ethylene dibromide (EDB) • methylene chloride • <u>PAHs</u>: total naphthalene plus monomethylnaphthalenes • Phenols • Polychlorinated biphenyls (PCBs) • toluene • 1,1,2,2-tetrachloroethane • 1,1,2,2-tetrachloroethylene (PCE) • 1,1,1-trichloroethane • 1,1,2-trichloroethane • 1,1,2-trichloroethylene (TCE) • vinyl chloride • xylenes (total) <p>Samples shall be properly prepared, preserved, transported and analyzed in accordance with the methods authorized in this Discharge Permit. Analytical results shall be submitted to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
29.	<p>Records of solids disposal, including the volume of solids removed, and copies of all manifests for the previous calendar year shall be submitted to NMED annually in the monitoring report due by August 1st each year.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>

C. CONTINGENCY PLAN

#	Terms and Conditions
30.	<p>In the event that a groundwater quality standard identified in Section 20.6.2.3103 NMAC is exceeded, the total nitrogen concentration in groundwater exceeds 10 mg/L, or a toxic pollutant as defined in Subsection WW of 20.6.2.7 NMAC is present in groundwater during the term of this Discharge Permit, upon closure of the facility or during the implementation of post-closure requirements, the permittee shall submit to NMED a corrective action plan that proposes, at a minimum, source control measures and an implementation schedule. The plan shall be enacted as approved by NMED.</p> <p>The permittee may be required to abate water pollution pursuant to Sections 20.6.2.4000 through 20.6.2.4115 NMAC, should the corrective action plan not result in compliance with the standards and requirements set forth in Section 20.6.2.4103 NMAC within 180</p>

#	Terms and Conditions
	<p>days of confirmation of groundwater contamination.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]</p>
31.	<p>In the event that analytical results of a quarterly treated wastewater sample indicate an exceedance of the total nitrogen discharge limit set in this Discharge Permit, the permittee shall collect and analyze a second sample within 48 hours of the receipt of the initial sampling results. In the event the second sample results indicate that the discharge limit is continuing to be exceeded, the following contingency plan shall be enacted.</p> <ul style="list-style-type: none"> a) Within 7 days of the second sample analysis date indicating that the discharge limit is continuing to be exceeded, the permittee shall: <ul style="list-style-type: none"> i) notify NMED that the contingency plan is being enacted; and ii) submit a copy of the first and second analytical results indicating an exceedance to NMED. b) The permittee shall increase the frequency of total nitrogen wastewater sampling and analysis of treated wastewater to once per month. c) The permittee shall examine the operation and maintenance log, required by the Record Keeping conditions of this Discharge Permit, for improper operational procedures. d) The permittee shall conduct a physical inspection of the treatment system to detect abnormalities. Any abnormalities discovered shall be corrected. A report detailing the corrections made shall be submitted to NMED within 30 days of correction. e) In the event that analytical results from weekly wastewater sampling indicate a continued exceedance of the total nitrogen discharge limit, the permittee shall propose to modify operational procedures and/or upgrade the treatment process to achieve the total nitrogen limit by submitting a corrective action plan to NMED for approval. The plan shall include a schedule for completion of corrective actions and shall be submitted within 90 days of the second sample analysis date indicating that the discharge limit is continuing to be exceeded. The permittee shall initiate implementation of the plan following approval by NMED. <p>When analytical results from three consecutive months of wastewater sampling do not exceed the discharge limit, the permittee is authorized to return to a quarterly monitoring frequency.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
32.	<p>In the event that analytical results of a reclaimed domestic wastewater sample indicate an exceedance of any of the maximum discharge limits BOD₅, TSS, or fecal coliform bacteria set by this Discharge Permit, the permittee shall collect and analyze a second sample within 24 hours of the receipt of the initial sampling results. In the event the second sample results indicate that any maximum discharge limit is continuing to be exceeded (i.e., confirmed exceedance), the contingency plan below shall be enacted.</p>

#	Terms and Conditions
	<p style="text-align: center;">AND / OR</p> <p>In the event that analytical results of a reclaimed domestic wastewater sample indicate an exceedance of any of the 30-day average discharge limits for BOD₅, TSS, or fecal coliform bacteria set by this Discharge Permit (i.e., confirmed exceedance), the contingency plan below shall be enacted.</p> <p><u>Contingency Plan</u></p> <ol style="list-style-type: none"> a) Within 24 hours of becoming aware of a confirmed exceedance (as identified above), the permittee shall: <ol style="list-style-type: none"> i) notify NMED that the contingency plan is being enacted; and ii) submit copies of the recent analytical results indicating an exceedance to NMED. b) The permittee shall immediately cease discharging reclaimed domestic wastewater to Lake 5W. Wastewater shall be discharged to Impoundment #1. c) The permittee shall examine the operation and maintenance log, required by the Record Keeping conditions of this Discharge Permit, for improper operational procedures. d) The permittee shall conduct a physical inspection of the treatment system to detect abnormalities. Any abnormalities discovered shall be corrected. A report detailing the corrections made shall be submitted to NMED within 30 days following correction. <p>When the analytical results from samples of reclaimed domestic wastewater, sampled as required by this Discharge Permit, no longer indicate an exceedance of any of the maximum discharge limits, the permittee may resume discharging reclaimed wastewater to Lake 5W.</p> <p>If a facility is required to enact the contingency plan more than two times in a 12-month period, the permittee shall propose to modify operational procedures and/or upgrade the treatment process to achieve consistent compliance with the maximum and 30-day average discharge limits by submitting a corrective action plan for NMED approval. The plan shall include a schedule for completion of corrective actions and shall be submitted within 60 days following the second sample analysis date. The permittee shall initiate implementation of the plan following approval by NMED. Prior to recommencing discharge to Lake 5W, additional sampling of any stored reclaimed wastewater may be required by NMED in response to the submitted corrective action plan.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
33.	<p>In the event that analytical results of an annual reclaimed wastewater sample indicate an exceedance of one or more of the discharge limits listed in Condition #5 of this Discharge Permit, the permittee shall collect and analyze a second sample for that constituent(s) within seven days of the receipt of the initial sampling results. In the</p>

#	Terms and Conditions
	<p>event the second sample results indicate that the discharge limit is continuing to be exceeded, the following contingency plan shall be enacted.</p> <ul style="list-style-type: none"> a) Within 24 hours of the second sample analysis date indicating that the discharge limit(s) is continuing to be exceeded, the permittee shall: <ul style="list-style-type: none"> i) notify NMED that the contingency plan is being enacted; and ii) submit a copy of the first and second analytical results indicating an exceedance to NMED. b) The permittee shall immediately cease discharging reclaimed domestic wastewater to Lake 5W. Wastewater shall be discharged to Impoundment #1. c) The permittee shall examine the operation and maintenance log, required by the Record Keeping conditions of this Discharge Permit, for improper operational procedures. d) The permittee shall conduct a physical inspection of the treatment system to detect abnormalities. Any abnormalities discovered shall be corrected. A report detailing the corrections made shall be submitted to NMED within 30 days of correction. <p>When the analytical results from samples of reclaimed wastewater, sampled as required by this Discharge Permit, no longer indicate an exceedance of any of the discharge limits listed in Condition 7 of this Discharge Permit, the permittee may resume discharging reclaimed wastewater to Lake 5W.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
34.	<p>In the event that inspection findings reveal significant damage likely to affect the structural integrity of Impoundment #1 or its ability to contain contaminants, the permittee shall propose the repair or replacement of the impoundment liner(s) by submitting a corrective action plan to NMED for approval. The plan shall be submitted to NMED within 30 days after discovery by the permittee or following notification from NMED that significant liner damage is evident. The corrective action plan shall include a schedule for completion of corrective actions and the permittee shall initiate implementation of the plan following approval by NMED.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
35.	<p>In the event that a minimum of two feet of freeboard cannot be preserved in Impoundment #1, the permittee shall take actions authorized by this Discharge Permit and all applicable local, state, and federal regulations to restore the required freeboard.</p> <p>In the event that two feet of freeboard cannot be restored within a period of 72 hours following discovery, the permittee shall propose actions to be immediately implemented to restore two feet of freeboard by submitting a short-term corrective action plan to NMED for approval. Examples of short-term corrective actions include removing excess wastewater from the impoundment through pumping and hauling, or reducing the volume of wastewater discharged to the impoundment. The plan shall include a</p>

#	Terms and Conditions
	<p>schedule for completion of corrective actions and shall be submitted within 15 days following the date when the two feet of freeboard limit was initially discovered. The permittee shall initiate implementation of the plan following approval by NMED.</p> <p>In the event that the short-term corrective actions failed to restore two feet of freeboard, the permittee shall propose permanent corrective actions in a long-term corrective action plan submitted to NMED within 90 days following failure of the short-term corrective action plan. Examples include the installation of an additional storage impoundment, or a significant/permanent reduction in the volume of wastewater discharged to the impoundment. The plan shall include a schedule for completion of corrective actions and implementation of the plan shall be initiated following approval by NMED.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
36.	<p>In the event that a release (commonly known as a “spill”) occurs that is not authorized under this Discharge Permit, the permittee shall take measures to mitigate damage from the unauthorized discharge and initiate the notifications and corrective actions required in Section 20.6.2.1203 NMAC and summarized below.</p> <p>Within <u>24 hours</u> following discovery of the unauthorized discharge, the permittee shall verbally notify NMED and provide the following information.</p> <ol style="list-style-type: none"> The name, address, and telephone number of the person or persons in charge of the facility, as well as of the owner and/or operator of the facility. The name and address of the facility. The date, time, location, and duration of the unauthorized discharge. The source and cause of unauthorized discharge. A description of the unauthorized discharge, including its estimated chemical composition. The estimated volume of the unauthorized discharge. Any actions taken to mitigate immediate damage from the unauthorized discharge. <p>Within <u>one week</u> following discovery of the unauthorized discharge, the permittee shall submit written notification to NMED with the information listed above and any pertinent updates.</p> <p>Within <u>15 days</u> following discovery of the unauthorized discharge, the permittee shall submit a corrective action report/plan to NMED describing any corrective actions taken and/or to be taken relative to the unauthorized discharge that includes the following information.</p> <ol style="list-style-type: none"> A description of proposed actions to mitigate damage from the unauthorized discharge. A description of proposed actions to prevent future unauthorized discharges of this nature. A schedule for completion of proposed actions.

#	Terms and Conditions
	<p>In the event that the unauthorized discharge causes or may with reasonable probability cause water pollution in excess of the standards and requirements of Section 20.6.2.4103 NMAC, and the water pollution will not be abated within 180 days after notice is required to be given pursuant to Paragraph (1) of Subsection A of 20.6.2.1203 NMAC, the permittee may be required to abate water pollution pursuant to Sections 20.6.2.4000 through 20.6.2.4115 NMAC.</p> <p>Nothing in this condition shall be construed as relieving the permittee of the obligation to comply with all requirements of Section 20.6.2.1203 NMAC.</p> <p>[20.6.2.1203 NMAC]</p>
37.	<p>In the event that NMED or the permittee identifies any failures of the discharge plan or this Discharge Permit not specifically noted herein, NMED may require the permittee to submit a corrective action plan and a schedule for completion of corrective actions to address the failure(s). Additionally, NMED may require a Discharge Permit modification to achieve compliance with 20.6.2 NMAC.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]</p>

D. CLOSURE PLAN

#	Terms and Conditions
38.	<p>In the event a facility, or a component of a facility, is proposed to be permanently closed, upon ceasing discharging, the permittee shall perform the following closure measures.</p> <p>Within <u>90 days</u> of ceasing discharging to the treatment system, the permittee shall complete the following closure measures.</p> <ul style="list-style-type: none"> a) The line leading to the system shall be plugged so that a discharge can no longer occur. b) Wastewater in the system components and storage impoundment(s) shall be evaporated, or drained and disposed of in accordance with all local, state, and federal regulations. c) Solids removed from the treatment system shall be contained, transported, and disposed of in accordance with all local, state, and federal regulations, including 40 CFR Part 503. The permittee shall maintain a record of all solids transported for off-site disposal. <p>Within <u>180 days</u> of ceasing discharging to the treatment system (or unit), the permittee shall complete the following closure measures.</p>

#	Terms and Conditions
	<p>a) Remove all lines leading to and from the treatment system, or permanently plug them and abandon them in place.</p> <p>b) Remove or demolish all treatment system components, and re-grade area with suitable fill to blend with surface topography, promote positive drainage and prevent ponding.</p> <p>c) Perforate or remove the storage impoundment liner(s); fill the impoundment(s) with suitable fill; and re-grade the impoundment site(s) to blend with surface topography, promote positive drainage and prevent ponding.</p> <p>When all closure and post-closure requirements have been met, the permittee may submit a written request for termination of the Discharge Permit to NMED.</p> <p>[Subsection A of 20.6.2.3107 NMAC, 40 CFR Part 503]</p>

E. GENERAL TERMS AND CONDITIONS

#	Terms and Conditions
39.	<p>RECORD KEEPING - The permittee shall maintain a written record of:</p> <ul style="list-style-type: none"> • information and data used to complete the application for this Discharge Permit; • any releases (commonly known as "spills") not authorized under this Discharge Permit and reports submitted pursuant to 20.6.2.1203 NMAC; • the operation, maintenance, and repair of all facilities/equipment used to treat, store or dispose of wastewater; • facility record drawings (plans and specifications) showing the actual construction of the facility and bear the seal and signature of a licensed New Mexico professional engineer; • copies of monitoring reports completed and/or submitted to NMED pursuant to this Discharge Permit; • the volume of wastewater or other wastes discharged pursuant to this Discharge Permit; • groundwater quality and wastewater quality data collected pursuant to this Discharge Permit; • copies of construction records (well log) for all groundwater monitoring wells required to be sampled pursuant to this Discharge Permit; • the maintenance, repair, replacement or calibration of any monitoring equipment or flow measurement devices required by this Discharge Permit; and • data and information related to field measurements, sampling, and analysis conducted pursuant to this Discharge Permit, including: <ul style="list-style-type: none"> ○ the dates, location and times of sampling or field measurements; ○ the name and job title of the individuals who performed each sample collection or field measurement;

#	Terms and Conditions
	<ul style="list-style-type: none"> ○ the sample analysis date of each sample; ○ the name and address of the laboratory, and the name of the signatory authority for the laboratory analysis; ○ the analytical technique or method used to analyze each sample or collect each field measurement; ○ the results of each analysis or field measurement, including raw data; ○ the results of any split, spiked, duplicate or repeat sample; and ○ a copy of the laboratory analysis chain-of-custody as well as a description of the quality assurance and quality control procedures used. <p>The written record shall be maintained by the permittee at a location accessible during a facility inspection by NMED for a period of at least five years from the date of application, report, collection or measurement and shall be made available to the department upon request.</p> <p>[Subsections A and D of 20.6.2.3107 NMAC]</p>
40.	<p>INSPECTION and ENTRY – The permittee shall allow inspection by NMED of the facility and its operations that are subject to this Discharge Permit and the WQCC regulations. NMED may upon presentation of proper credentials, enter at reasonable times upon or through any premises in which a water contaminant source is located or in which are located any records required to be maintained by regulations of the federal government or the WQCC.</p> <p>The permittee shall allow NMED to have access to and reproduce for their use any copy of the records, and to perform assessments, sampling or monitoring during an inspection for the purpose of evaluating compliance with this Discharge Permit and the WQCC regulations.</p> <p>Nothing in this Discharge Permit shall be construed as limiting in any way the inspection and entry authority of NMED under the WQA, the WQCC Regulations, or any other local, state or federal regulations.</p> <p>[Subsection D of 20.6.2.3107 NMAC, NMSA 1978, §§ 74-6-9.B and 74-6-9.E]</p>
41.	<p>DUTY to PROVIDE INFORMATION - The permittee shall, upon NMED's request, allow for NMED's inspection/duplication of records required by this Discharge Permit and/or furnish to NMED copies of such records.</p> <p>[Subsection D of 20.6.2.3107 NMAC]</p>
42.	<p>MODIFICATIONS and/or AMENDMENTS – In the event the permittee proposes a change to the facility or the facility's discharge that would result in a change in the volume discharged; the location of the discharge; or in the amount or character of water</p>

#	Terms and Conditions
	<p>contaminants received, treated or discharged by the facility, the permittee shall notify NMED prior to implementing such changes. The permittee shall obtain approval (which may require modification of this Discharge Permit) by NMED prior to implementing such changes.</p> <p>[Subsection C of 20.6.2.3107 NMAC, Subsections E and G of 20.6.2.3109 NMAC]</p>
43.	<p>PLANS and SPECIFICATIONS – In the event the permittee is proposing to construct a wastewater system or change a process unit of an existing system such that the quantity or quality of the discharge will change substantially from that authorized by this Discharge Permit, the permittee shall submit construction plans and specifications to NMED for the proposed system or process unit prior to the commencement of construction.</p> <p>In the event the permittee implements changes to the wastewater system authorized by this Discharge Permit that result in only a minor effect on the character of the discharge, the permittee shall report such changes (including the submission of record drawings, where applicable) as of January 1 and June 30 of each year to NMED.</p> <p>[Subsections A and C of 20.6.2.1202 NMAC, NMSA 1978, §§ 61-23-1 through 61-23-32]</p>
44.	<p>CIVIL PENALTIES - Any violation of the requirements and conditions of this Discharge Permit, including any failure to allow NMED staff to enter and inspect records or facilities, or any refusal or failure to provide NMED with records or information, may subject the permittee to a civil enforcement action. Pursuant to WQA 74-6-10(A) and (B), such action may include a compliance order requiring compliance immediately or in a specified time, assessing a civil penalty, modifying or terminating the Discharge Permit, or any combination of the foregoing; or an action in district court seeking injunctive relief, civil penalties, or both. Pursuant to WQA 74-6-10(C) and 74-6-10.1, civil penalties of up to \$15,000 per day of noncompliance may be assessed for each violation of the WQA 74-6-5, the WQCC Regulations, or this Discharge Permit, and civil penalties of up to \$10,000 per day of noncompliance may be assessed for each violation of any other provision of the WQA, or any regulation, standard, or order adopted pursuant to such other provision. In any action to enforce this Discharge Permit, the permittee waives any objection to the admissibility as evidence of any data generated pursuant to this Discharge Permit.</p> <p>[20.6.2.1220 NMAC, NMSA 1978, §§ 74-6-10 and 74-6-10.1]</p>
45.	<p>CRIMINAL PENALTIES – No person shall:</p> <ul style="list-style-type: none"> • make any false material statement, representation, certification or omission of material fact in an application, record, report, plan or other document filed, submitted or required to be maintained under the WQA; • falsify, tamper with or render inaccurate any monitoring device, method or record

#	Terms and Conditions
	<p>required to be maintained under the WQA; or</p> <ul style="list-style-type: none"> fail to monitor, sample or report as required by a permit issued pursuant to a state or federal law or regulation. <p>Any person who knowingly violates or knowingly causes or allows another person to violate the requirements of this condition is guilty of a fourth degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who is convicted of a second or subsequent violation of the requirements of this condition is guilty of a third degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who knowingly violates the requirements of this condition or knowingly causes another person to violate the requirements of this condition and thereby causes a substantial adverse environmental impact is guilty of a third degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who knowingly violates the requirements of this condition and knows at the time of the violation that he is creating a substantial danger of death or serious bodily injury to any other person is guilty of a second degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15.</p> <p>[20.6.2.1220 NMAC, NMSA 1978, §§ 74-6-10.2.A through 74-6-10.2.F]</p>
46.	<p>COMPLIANCE with OTHER LAWS - Nothing in this Discharge Permit shall be construed in any way as relieving the permittee of the obligation to comply with all applicable federal, state, and local laws, regulations, permits or orders.</p> <p>[NMSA 1978, § 74-6-5.L]</p>
47.	<p>RIGHT to APPEAL - The permittee may file a petition for review before the WQCC on this Discharge Permit. Such petition shall be in writing to the WQCC within thirty days of the receipt of postal notice of this Discharge Permit and shall include a statement of the issues to be raised and the relief sought. Unless a timely petition for review is made, the decision of NMED shall be final and not subject to judicial review.</p> <p>[20.6.2.3112 NMAC, NMSA 1978, § 74-6-5.O]</p>
48.	<p>TRANSFER of DISCHARGE PERMIT - Prior to the transfer of any ownership, control, or possession of this facility or any portion thereof, the permittee shall:</p> <ul style="list-style-type: none"> notify the proposed transferee in writing of the existence of this Discharge Permit; include a copy of this Discharge Permit with the notice; and deliver or send by certified mail to NMED a copy of the notification and proof that such notification has been received by the proposed transferee. <p>Until both ownership and possession of the facility have been transferred to the</p>

#	Terms and Conditions
	transferee, the permittee shall continue to be responsible for any discharge from the facility. [20.6.2.3111 NMAC]
49.	<p>PERMIT FEES - Payment of permit fees is due at the time of Discharge Permit approval. Permit fees shall be paid in a single payment or shall be paid in equal installments on a yearly basis over the term of the Discharge Permit. Single payments shall be remitted to NMED no later than 30 days after the Discharge Permit effective date. Initial installment payments shall be remitted to NMED no later than 30 days after the Discharge Permit effective date; subsequent installment payments shall be remitted to NMED no later than the anniversary of the Discharge Permit effective date.</p> <p>Permit fees are associated with <u>issuance</u> of this Discharge Permit. Nothing in this Discharge Permit shall be construed as relieving the permittee of the obligation to pay all permit fees assessed by NMED. A permittee that ceases discharging or does not commence discharging from the facility during the term of the Discharge Permit shall pay all permit fees assessed by NMED. An approved Discharge Permit shall be suspended or terminated if the facility fails to remit an installment payment by its due date.</p> <p>[Subsection F of 20.6.2.3114 NMAC, NMSA 1978, § 74-6-5.K]</p>

V. PERMIT TERM & SIGNATURE

EFFECTIVE DATE: [effective date]

TERM ENDS: [expiration date]

[Subsection H of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.I]

MICHELLE HUNTER
Chief, Ground Water Quality Bureau
New Mexico Environment Department



New Mexico Environment Department Ground Water Quality Bureau Discharge Permit Summary

Facility Information

Facility Name
Discharge Permit Number

Las Campanas Water and Sewer Cooperative
DP-944

Legally Responsible Party

Kimberly Visser-Weinmann, General Manager
Las Campanas Water and Sewer Cooperative
366 Las Campanas Drive
Santa Fe, New Mexico 87506
(505) 204-7829

Treatment, Disposal and Site Information

Primary Waste Type
Facility Type

Domestic Wastewater
Private Wastewater Treatment Plant

Treatment Methods

Type	Designation	Description & Comments
Wastewater Treatment Plant	WWTP	Headworks: Mechanical Bar Screen with By-Pass Manual Bar Screen; Grit Chamber; Influent Parshall Flume with Ultrasonic Head Sensor and Data Logger Activated Sludge Treatment System: One Aerated Equalization Basin; Two Sequencing Batch Reactors Disinfection: Chlorine and Sand Filters

Discharge Locations

Type	Designation	Description & Comments
Impoundment	Impoundment #1	Synthetically-lined and located on the property of the Las Campanas Water and Sewer Cooperative
Impoundment	Lake 5W	Synthetically-lined and located on the property of The Club at Las Campanas

Flow Metering Locations

Type	Designation	Description & Comments
Primary Measurement Device	Influent Meter	Parshall Flume with ultrasonic head sensor and data logger located on the influent line to the WWTP
Totalizing Flow Meter	Primary Meter	Totalizing flow meter on the discharge line to Lake 5W
Totalizing Flow Meter	Secondary Meter	Totalizing flow meter on the discharge line to Impoundment #1

Depth-to-Ground Water
Total Dissolved Solids (TDS)

278 feet
300 mg/L



**New Mexico Environment Department Ground Water Quality Bureau
Discharge Permit Summary**

Permit Information

Application Received	February 10, 2012
Public Notice Published	[not yet published]
Discharge Permit Issued	[effective date]
Discharge Permit Term Ends	[term end date]
Permitted Discharge Volume	320,000 gallons per day

NMED Contact Information

Mailing Address	Ground Water Quality Bureau P.O. Box 5469 Santa Fe, New Mexico 87502-5469
GWQB Telephone Number	(505) 827-2900
NMED Lead Staff	R. Brian Schall
Lead Staff Telephone Number	(505) 476-3648
Lead Staff Email	brian.schall@state.nm.us